

Sika Limited

Sika House
Miller Street
Preston
Lancashire PR1 1EA

Tel: 01772 259781 Fax: 01772 255670

e-mail: iqidplastics@uk.sika.com

website: www.liquidplastics.co.uk



Agrément Certificate

16/5294

Product Sheet 3

SIKALASTIC ROOF WATERPROOFING SYSTEMS

SIKALASTIC -625N FULLY-REINFORCED SYSTEM

This Agrément Certificate Product Sheet⁽¹⁾ relates the Sikalastic -625N Fully-Reinforced System, consisting of a moisture triggered aliphatic polyurethane, for use as a glass fibre-reinforced waterproofing on flat roofs with limited access.

(1) Hereinafter referred to as 'Certificate'.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.

KEY FACTORS ASSESSED

Weathertightness — the system will resist the passage of moisture to the interior of a building (see section 6).

Properties in relation to fire — the system can enable a roof to be unrestricted under the national Building Regulations (see section 7).

Adhesion — the adhesion of the system is sufficient to resist the effects of any likely wind suction and the effects of thermal or other minor movement likely to occur in practice (see section 8).

Resistance to mechanical damage — the system will accept, without damage, the limited foot traffic and loads associated with installation and maintenance (see section 9).

Durability — under normal service conditions, the system will provide a durable waterproof covering with a service life of at least 25 years (see section 11).



The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of First issue: 11 May 2020

Hardy Giesler
Chief Executive Officer

The BBA is a UKAS accredited certification body – Number 113.

The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk
Readers MUST check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Board of Agrément

Bucknalls Lane
Watford
Herts WD25 9BA

©2020

tel: 01923 665300
clientservices@bbacerts.co.uk
www.bbacerts.co.uk

Regulations

In the opinion of the BBA, the Sikalastic -625N Fully-Reinforced System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement:	B4(2)	External fire spread
Comment:		On a suitable substructure, the system can enable a roof to be unrestricted under this Requirement. See section 7 of this Certificate.
Requirement:	C2(b)	Resistance to moisture
Comment:		The system will enable a roof to satisfy this Requirement. See section 6.1 of this Certificate.
Regulation:	7(1)	Materials and workmanship
Comment:		The system is acceptable. See section 11 and the <i>Installation</i> part of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8(1)(2)	Durability, workmanship and fitness of materials
Comment:		The use of the system satisfies the requirements of this Regulation. See sections 10.1 and 11 and the <i>Installation</i> part of this Certificate.
Regulation:	9	Building standards applicable to construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		The system, when applied to a suitable structure, can be regarded as having low vulnerability under clause 2.8.1 ⁽¹⁾⁽²⁾ of this Standard. See section 7 of this Certificate.
Standard:	3.10	Precipitation
Comment:		The use of the system will enable a roof to satisfy the requirements of this Standard with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ . See section 6.1 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The system can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6 and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.
Regulation:	12	Building standards applicable to conversions
Comment:		Comments in relation to the system under Regulation 9, Standards 1 to 6 also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ .

(1) Technical Handbook (Domestic).

(2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation:	23(a)(b)(i)	Fitness of materials and workmanship
Comment:		The system is acceptable. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation:	28(b)	Resistance to moisture and weather
Comment:		The system will enable a roof to satisfy the requirements of this Regulation. See section 6.1 of this Certificate.

Regulation:	36(b)	External fire spread
Comment:		On suitable substructures, the use of the system can enable a roof to be unrestricted under this Regulation. See section 7 of this Certificate.

Construction (Design and Management) Regulations 2015 Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

See section: *3 Delivery and site handling* of this Certificate.

Additional Information

NHBC Standards 2020

In the opinion of the BBA, the Sikalastic -625N Fully-Reinforced System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapter 7.1 *Flat roofs and balconies*.

CE marking

The Certificate holder has taken the responsibility of CE marking the system, in accordance with European Technical Approval 20/0073, issued by the BBA under ETAG 005 : 2005, Parts 1 and 6.

Registered office

The registered office of the Certificate holder is Sika Limited, Watchmead, Welwyn Garden City, Hertfordshire AL7 1BQ (registered in England under company number 226822).

Technical Specification

1 Description

1.1 Sikalastic -625N Fully-Reinforced System consists of:

- Sikalastic -625N — a one-part, moisture-triggered, aliphatic based polyurethane
- Sika Concrete Primer — a primer for concrete substrates
- Sika Concrete Primer LO — a low odour primer for concrete substrates
- Sika Metal Primer — a two-part primer for the treatment of previously untreated metal surfaces and for spot priming of areas of corroded metal after preparation
- Sika Bonding Primer — a primer for concrete substrates
- Sika Reemat Premium — a non-woven glass reinforcement
- Sika Flexitape Heavy — a nylon mesh for use at metal substrate joints
- Sikafloor -701 — a two-component epoxy primer, levelling mortar and mortar screed binder.

1.2 The levels of Use Categories in accordance with ETAG 005 : 2000 from ETA 20/0073 are:

External fire performance	B _{ROOF} (t1), B _{ROOF} (t4)
Reaction to fire	Euroclass E
Categorisation by working life	W3 (25 years)
Categorisation by climatic zone	M (moderate) and S(severe)
Categorisation by imposed loads	P3 (normal) to P4 (special)
Categorisation by roof slope	S1 (<5%) to S4 (>30%)
Categorisation by surface temperature	
lowest	TL4 (−30°C)
highest	TH4 (90°C)
Resistance to wind loads	>50kPa.

1.3 A proprietary carrier membrane is used over substrates with joints, such as insulation boards or plywood decking, and beneath the waterproofing system. The Certificate holder's Technical Services should be contacted for further advice.

2 Manufacture

2.1 The liquid components of the system are manufactured by a batch-blending process.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

2.3 The management system of Sika Limited has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2015 and BS EN ISO 14001 : 2015 by SGS (Certificates CH18/1439 and CH18/1439 respectively).

3 Delivery and site handling

3.1 The Sikalastic -625N liquid component is delivered to site in 5 or 15 litre tins bearing the product's name, batch number and the BBA logo incorporating the number of this Certificate.

3.2 The liquid component should be stored in a dry, shaded area, above freezing point and away from ignition sources. Storage temperatures of between 10 and 25°C will give the component a shelf-life of 12 months; at higher temperatures the shelf-life will reduce progressively. Once opened, tins should be used within two or three days.

3.3 The Certificate holder has taken the responsibility of classifying and labelling the system components under the *CLP Regulation (EC) No 1272/2008 on the classification, labelling and packaging of substances and mixtures*. Users must refer to the relevant Safety Data Sheet(s).

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on the Sikalastic -625N Fully-Reinforced System.

Design Considerations

4 General

4.1 The Sikalastic -625N Fully-Reinforced System is satisfactory for use as a system on flat roofs with limited access on:

- concrete (primed and unprimed)
- asphalt
- bituminous roofing membranes, including mineral surfaced
- galvanized steel
- non-mineralised bitumen roofing membranes on plywood
- liquid-applied bituminous roof coating
- aluminium paint
- polyisocyanurate (PIR) foam insulation boards in conjunction with a specified carrier membrane
- existing polyurethane roofs.

4.2 Decks to which the system is to be applied must comply with the relevant requirements of BS 6229 : 2018 and, where appropriate, *NHBC Standards 2020*, Chapter 7.1.

4.3 The system must not be applied directly to, nor come into contact with, polystyrene insulation products.

4.4 Limited access roofs are defined for the purpose of this Certificate as those subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc, where traffic in excess of this is envisaged, special precautions, such as additional protection, must be taken.

4.5 Flat roofs are defined for the purpose of this Certificate as those having a minimum finished fall of 1:80. When designing flat roofs, twice the minimum finished fall should be assumed unless a detailed analysis of the roof is available, including overall and local deflection, direction of falls, etc.

4.6 Pitched roofs are defined for the purpose of this Certificate as those having falls in excess of 1:6.

5 Practicability of installation

Installation of the system must be carried out only by specialist roofing contractors trained and approved by the Certificate holder.

6 Weathertightness



6.1 The system will adequately resist the passage of moisture to the interior of a building and so satisfy the relevant requirements of the national Building Regulations.

6.2 The system is impervious to water and, when used as described, will give a weathertight roofing capable of accepting minor movement without damage.

6.3 To achieve a weathertight coating it is essential that the application rate quoted in the Certificate holder's installation instructions is applied.

7 Properties in relation to fire



7.1 When tested to DD CEN/TS 1187 : 2012, Test 4, and classified in accordance with BS EN 13501-5 : 2016, the following specifications achieved a $B_{ROOF}(t4)$ classification:

- a 12 mm thick primed plywood substrate, 0.6 mm thick self-adhesive vapour control layer, a 80 mm thick glass faced, polyisocyanurate insulation board adhered with a polyurethane adhesive and primed, a 0.6 mm thick self-adhesive carrier membrane, a base coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2}$, a layer of Sika Reemat Premium, and a top coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2(1)}$
- a system comprising a 6 mm calcium silicate board, a 2.6 mm thick SBS modified bitumen roofing membrane, a base coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2}$, a layer of Sika Reemat Premium and a top coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2(2)}$
- a system comprising a 6 mm calcium silicate board, a base coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2}$, a layer of Sika Reemat Premium and a top coat of Sikalastic -625N at an application rate of $1.0 \text{ l}\cdot\text{m}^{-2(3)}$.

(1) Fire test and classification reports, reference 19823B and 19823C respectively, conducted by Warringtonfire. Report available from the Certificate holder.

(2) Fire test and classification reports, reference 19823F and 19823G respectively, conducted by Warringtonfire. Report available from the Certificate holder.

(3) Fire test and classification reports, reference 19823K and 19823L respectively, conducted by Warringtonfire. Report available from the Certificate holder.

7.2 The designation of other specifications should be confirmed by reference to the requirements of the documents supporting the national Building Regulations.

8 Adhesion

The adhesion of the system to the substrates and finishes indicated in section 4.1 is sufficient to resist the effects of any wind suction, elevated temperatures, thermal shock or minor movement likely to occur in practice.

9 Resistance to mechanical damage

The system can accept, without damage, the limited foot traffic and light concentrated loads associated with installation and maintenance. However, reasonable care should be taken to avoid puncture by sharp objects or concentrated loads.

10 Maintenance



10.1 The system should be the subject of six monthly inspections and maintenance in accordance with BS 6229 : 2018, Chapter 7, to ensure continued satisfactory performance.

10.2 Any damage should be repaired in accordance with section 15 of this Certificate and the Certificate holder's instructions.

11 Durability



The system will provide a durable waterproof covering with a service life of at least 25 years

Installation

12 General

12.1 Installation of the Sikalastic -625N Fully-Reinforced System must be carried out only by specialist roofing contractors trained and approved by the Certificate holder, in accordance with the relevant clauses of BS 8000-0 : 2014, BS 8000-4 : 1989 and the Certificate holder's instructions.

12.2 The system components must be at a temperature of, or greater than, 10°C for airless spray applications. All components must be applied when the air and substrate temperatures are greater than 5°C. Special precautions may be necessary when temperatures exceed 35°C, as shown in the Certificate holder's Technical Data Sheets.

12.3 Detailing (eg upstands) is carried out in accordance with the Certificate holder's instructions.

13 Site and surface preparation

13.1 Substrates on which the system is to be applied must be properly prepared in accordance with the Certificate holder's instructions.

13.2 Adhesion to substrates will depend on the condition and cleanness of the substrate. Substrates must be visibly dry, sound and free from loose materials or contamination (eg moss or algae). The surface must be prepared to remove loose or flaking materials, but the substrate must be visibly dry before application of the system.

13.3 Damaged areas of the substrate (eg blistered membrane) must be removed, replaced or repaired. Substrate defects (eg shallow-bottomed cracks and indentations) are filled in accordance with the Certificate holder's instructions.

13.4 Deck surfaces must be free from sharp projections such as concrete nibs.

13.5 Gutters and outlets must be checked to ensure that they are, and remain, clear of all debris.

13.6 All points of potential weakness such as splits, cracks, joints and crazed surfaces must be additionally reinforced in accordance with the Certificate holder's instructions prior to application of the main system.

13.7 Priming requirements of the substrate should be checked and carried out in accordance with the Certificate holder's instructions.

14 Procedure

14.1 Application can be by brush, roller or spray. Brush application is normally used only for small roof areas and, when used, for embedding Sika Reemat Premium Reinforcing Mat into the waterproofing at areas of detailing.

14.2 Prior to application, checks must be made to ensure the substrate is dry (ie free from rainwater, surface condensation and frost) and that the prevailing weather and site conditions are correct. The following normal limitations apply:

- application must not take place when the relative humidity is in excess of 95%, or in fog. The temperature/humidity must be such that there is no risk of surface condensation occurring before or during application
- air and substrate temperatures must be in excess of 5°C
- Sikalastic -625N is conditioned at a temperature of 10°C or greater, for use in airless spray applications
- the primer, where used, must be cured
- the wind speed must be such that it does not interfere with the application or cause overspray. No attempt to spray should be made if the wind speed exceeds $6.7 \text{ m}\cdot\text{s}^{-1}$ (15 mph), unless precautions such as the use of wind barriers are taken.

14.3 Only areas that can be applied to the full thickness before weather changes occur should be attempted.

14.4 The system is applied at the coverage rate for a smooth texture substrate given in Table 1. The advice of the Certificate holder on coverage rates for intermediate, rough, porous and undulating substrates must be sought. When using the Sika Reemat Premium reinforcing mat, this is embedded in the first coat while the membrane is still wet. Once the first coat is partially cured the second coat is applied.

Layer (unit)	Full reinforcement system
Base coat ($\text{l}\cdot\text{m}^{-2}$)	1.0
Reinforcement	Sika Reemat Premium
Top coat ($\text{l}\cdot\text{m}^{-2}$)	1.0
Finished thickness (mm)	1.5

14.5 Random tests are carried out on the finished coating surface by cutting out small areas to measure finished cured thickness. Test areas must be repaired after the sample is taken.

15 Repair

The repair of minor damage to the system can be achieved effectively by cleaning back to the unweathered material and recoating the damaged area with the membrane at the recommended coverage rates given in section 14.4.

Technical Investigations

16 Tests

Tests were carried out and the results assessed to determine:

- water vapour transmission
- resistance to water penetration
- tensile strength and elongation
- tensile bond strength
- static indentation at 23 and 90°C
- dynamic indentation at -30 and 20°C

- resistance to fatigue movement
- crack bridging
- UV ageing for 25 year equivalent, followed by tensile strength and dynamic indentation
- heat ageing for 25 year equivalent, followed by tensile strength, dynamic indentation and fatigue cycling
- water exposure for 25 year equivalent, followed by tensile bond strength and static indentation.

17 Investigations

17.1 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of the materials used.

17.2 Data on fire performance were evaluated.

Bibliography

BS 6229 : 2018 *Flat roofs with continuously supported flexible waterproof coverings — Code of practice*

BS 8000-0 : 2014 *Workmanship on construction sites — Introduction and general principles*

BS 8000-4 : 1989 *Workmanship on building sites — Code of practice for waterproofing*

BS EN 13501-5 : 2016 *Fire classification of construction products and building elements — Classification using data from external fire exposure to roofs tests*

BS EN ISO 9001 : 2015 *Quality management systems — Requirements*

BS EN ISO 14001 : 2015 *Environmental management systems — Requirements with guidance for use*

ETAG 005 : 2000 Part 1 *Liquid applied roof waterproofing kits — General*

ETAG 005 : 2000 Part 6 *Liquid applied roof waterproofing kits — Specific stipulations*

DD CEN/TS 1187 : 2012 *Test methods for external fire exposure to roofs*

18 Conditions

18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

18.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

18.5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

18.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.